

**ADDENDUM# 1
EXTERIOR STAIR REPAIRS AT MORELY SCHOOL**

Bid # 6081F

June 26, 2009

Dear Vendors:

**The Contract Bidding Documents pursuant to Bid # 6081F are hereby revised as follows:
The following are responses to RFI's received:**

Q1: Will there be an addendum on removing shrubs?

A1: Removal of the shrubs shall be included in this project.

Q2: Will someone at town unload stairs from my truck?


A2: No. Contractor is responsible for all necessary to provide the install as specified in the contract bidding documents.

**Q3: We feel we cannot remove masonry cap without destroying the brick wall.
We could cut joint and install lead flashing?**

A3: The masonry caps shall be removed as the engineer has specified and shall include any and all restoration to the remaining brick wall as part of this project.

Thank you for your patience, time and consideration.

Sincerely,




Tammy Bradley, CPM, C.P.P.B.
Sr. Buyer

Enclosures

C: Joe Mercieri, Capitol Projects Manager
Mike Longo, Facilities Manager



TOWN OF WEST HARTFORD 50 SOUTH MAIN STREET
TOWN OF WEST HARTFORD, CT 06107-2431
(860) 561-7470 FAX: 561-7492

 Printed on Recycled Paper